

TRANSFORMER SERIES 0.35 VA




Transformer 50/60 Hz approval KEMA ENEC 05
 Approval KEMA on primary voltage 230 V n. licence 3502486.01
 Approval also with asymmetric secondary voltages
 Two chamber winding
 Class II IP00
 Insulation class Ta 70°B
 Short-circuit proof
 Potted under vacuum
 For according to the standard no series up 2x18 V



Standard voltages list, other voltages on request
 (for complete the code insert secondary voltage wanted)

CODE	PRIMARY	POWER	PIN	SECONDARY	PIN
24--0.35	24 V	0.35 VA	1-4	6....24 V	6-7
120--0.35	120 V	0.35 VA	1-4	6....24 V	6-7
230--0.35	230 V	0.35 VA	1-4	6....24 V	6-7



view of pins